

## ADDENDUM

### **\*\*ATTENTION INSTALLERS\*\***

NORDYNE has clarified the information on page 6 of the Installation Instructions that were supplied with the unit:

- Installing a filter drier is optional. However it is good practice to install a filter drier when replacing the evaporator and/or condenser of a system. The filter drier must be installed in strict accordance with the manufacturer's installation instructions.

**DISREGARD the information currently on page 6 and follow these guidelines instead.**

- It is proper installation practice and highly recommended to install a filter drier when the system is open to the atmosphere. This includes, but is not limited to, replacing the evaporator and/or condenser of a system. When installing the filter drier, it must be installed in strict accordance with the manufacturer's installation instructions.

