

INSTALLATION INSTRUCTIONS

FILTER STANDOFF KIT FOR B6BW & B6EW AIR HANDLERS

IMPORTANT SAFETY INFORMATION

Please read all instructions before installing these components. Pay attention to all safety warnings and any other special notes highlighted in the manual. Safety markings are used frequently throughout this manual to designate a degree or level of seriousness and should not be ignored.

WARNING indicates a potentially hazardous situation that if not avoided, could result in personal injury or death.

CAUTION indicates a potentially hazardous situation that if not avoided, may result in minor or moderate injury or property damage.

- The installer performing this work assumes all responsibility when installing this kit. These instructions are primarily intended to assist qualified individuals experienced in the proper installation of these components. Some local codes may require licensed installation/service personnel for this type of equipment. Safety should always be the deciding factor when installing this product and using common sense plays an important role as well. Improper installation of the components or failure to follow safety warnings could result in serious injury, death, or property damage.
- Unless noted otherwise in these instructions, only factory authorized parts or accessory kits may be used with this product. Improper installation, service, adjustment, or maintenance may cause fire, electrical shock or other hazardous conditions which may result in personal injury or property damage.
- Please read all instructions carefully before starting the installation. If a problem occurs, check the instructions and follow recommendations given.
- The information shown in these instructions must be followed during the installation of this kit. Unqualified individuals should not attempt to interpret these instructions or install this equipment. If you do not possess mechanical skills or tools, call your local dealer for assistance.
- Use caution when handling the appliance or removing components. Personal injury can occur from sharp metal edges present in all sheet metal constructed equipment.

FILTER STANDOFF INSTALLATION

WARNING:

RISK OF ELECTRICAL SHOCK

Shut off all electrical power to the unit before performing any maintenance or service on the system. Failure to follow this warning can cause serious injury, fire, electrical shock, or death.

1. Disconnect all power to the unit.
2. Remove door from front of unit.
3. Remove filter from the unit.
4. Remove left filter track from unit. **NOTE:** Do not discard the screws. Set them aside for future use.
5. Remove right filter track from unit. **NOTE:** Do not discard the screws. Set them aside for future use.
6. Place the left standoff on the coil frame in the same location that the left filter track was removed from in step 4.
7. Align the slots in the standoff with the screw holes in the coils frame and install the 2 screws that were removed in step 4. **NOTE:** Do not tighten the screws. Leave them loose for aligning standoffs in next step.
8. Place the right standoff on the coil frame in the same location that the right filter track was removed from in step 5.
9. Align the slots in the standoff with the screw holes in the coils frame and secure with the 2 screws removed in step 5. **NOTE:** Do not tighten the screws. Leave them loose for aligning standoffs in next step.
10. Place the top standoff on top of the left and right standoff.
11. Align the holes between the top standoff with the left and right standoff and install 1 screw at each end of the top standoff.
12. Tighten all screws to secure the top standoff, left standoff and right standoff.
13. Place the left filter track on the left standoff. Align the holes in the filter track and standoff. Secure with the 2 screws supplied in the kit.
14. Place the right filter track on the standoff. Align the holes in the filter track and standoff. Secure with the 2 screws supplied in the kit.
15. Slide the filter between both filter tracks.
16. Reinstall door on front of unit.

